

PROLIFERATION RESISTANCE CONSIDERATIONS FOR ADVANCED NUCLEAR ENERGY SYSTEMS

Enabling Energy Security through the Nuclear Fuel Cycle

James A. Morman

Big 10 Nuclear Engineering Departments Workshop Argonne National Laboratory, July 20-21, 2004

The submitted manuscript has been created by the University of Chicago as Operator of Argonne National Laboratory ("Argonne") under Contract No. W-31-109-ENG-38 with the U.S. Department of Energy. The U.S. Government retains for itself, and others acting on its behalf, a paid-up, nonexclusive, irrevocable worldwide license in said article to reproduce, prepare derivative works, distribute copies to the public, and perform publicly and display publicly, by or on behalf of the Government.

Argonne National Laboratory



A U.S. Department of Energy Office of Science Laboratory Operated by The University of Chicago





The results presented in the following presentation are based on research funded in part by the U. S. Department of Energy Office of Nuclear Energy, Science and Technology (NE) and the National Nuclear Security Administration (NA).

The submitted manuscript has been created by the University of Chicago as Operator of Argonne National Laboratory ("Argonne") under Contract No. W-31-109-ENG-38 with the U.S. Department of Energy. The U.S. Government retains for itself, and others acting on its behalf, a paid-up, nonexclusive, irrevocable worldwide license in said article to reproduce, prepare derivative works, distribute copies to the public, and perform publicly and display publicly, by or on behalf of the Government.





Proliferation Resistance

- The potential contribution of civilian nuclear systems to illicit uses of nuclear material has long been a concern
 - Non-Proliferation Treaty; Additional Protocol
 - Nuclear Suppliers Group
 - Recent Initiatives for Nuclear Energy expansion
 - IAEA (El-Baradei) and US (Bush) proposals
- Advanced nuclear energy systems are envisioned for widespread deployment during this century
 - Includes power plant and its fuel cycle
 - Potential widespread deployment (?) of fuel cycle facilities





Generation IV Systems

Generation IV Technology Goal:

Generation IV nuclear energy systems will increase the assurance that they are a very unattractive and the least desirable route for diversion or theft of weaponsusable materials, and provide increased physical protection against acts of terrorism.



Proliferation Resistance in Advanced Systems

- Advanced Nuclear Energy Systems must have robust proliferation resistance characteristics that make them the least desirable route to nuclear proliferation
- Assessing advanced systems for their potential to meet the Generation IV Goal requires a <u>definition of proliferation</u> resistance and a methodology to evaluate it





PR&PP Expert Group

A Proliferation Resistance and Physical Protection (PR&PP) Expert Group has been organized by US DOE NE and NNSA, with participation of GIF countries and International Organizations

Purpose – Develop and demonstrate a methodology for the systematic evaluation of Generation IV nuclear energy systems with respect to Proliferation Resistance and Physical Protection (Generation IV Technology Goal)

Main responsibilities

- Determine measures for expressing proliferation resistance
- Determine measures for expressing physical protection
- Develop a comprehensive evaluation approach





Methodology Development Scope

Scope based on two related end objectives identified in the Generation IV Roadmap

- Proliferation resistance
 - diversion of nuclear material from declared flows or inventories
 - undeclared production
 - replication of facilities/equipment
- Physical protection
 - theft of nuclear material for nuclear explosive devices or radiation dispersal devices
 - facility sabotage
 - transport sabotage





Gen IV Methodology Approach

- Systems are to be evaluated at different stages in their development for their potential to meet the technology goals.
 - This offers the opportunity to integrate PR&PP in the system design
- Systems will be evaluated for sustainability, safety, economics and PR&PP
 - PR&PP assessment methodology can be a tool to support it
- To the extent possible, a quantitative and standardized methodology is targeted
 - Include the ability to identify system features that contribute to the overall system PR&PP





Methodology Development

Methodology Development Tasks

- Establish the overall framework for the assessment
- Define the threat space for PR and for PP
- Identify PR&PP measures and metrics
- Develop a methodology to assess/quantify the metrics



Definitions and Functional Requirements

Proliferation Resistance (PR)

 That characteristic of a nuclear energy system that impedes the diversion or undeclared production of nuclear material, or misuse of technology, by States in order to acquire nuclear weapons or other nuclear explosive devices

Physical Protection (PP) robustness

 That characteristic of a nuclear energy system that impedes the theft of materials suitable for nuclear explosives or radiation dispersal devices, and the sabotage of facilities and transportation, by sub-national entities and other non-host state adversaries.

Functional requirements cover:

- Users and uses
- Application, capabilities
- Representation of results





Progressive Approach

Increasing level of design detail information about the system

Initial Phase

System information collection/organization

Threat space definition (actors and strategies)

Target identification

Coarse Path Analysis

Outcomes expressed in terms of numeric, linguistic measures

Determination of dominant paths

Progression

Stepwise refinements

- •Refine system information; develop database
- •Refine threat definition
- •Maintain modular structure for clarity and ease of use
- •Make paths increasingly system-specific
- •Move towards event trees functional event trees then systemic ones for ease of calculation
- •Maintain ability to decompose and understand quantitative results in terms of qualitative basis
- •Move toward more rigorous quantification of barrier properties
- •Use other methods (such as those described in NPAM report) to support quantification as appears useful
- •Refine decision analysis basis for comparing alternatives





Evaluation Framework

CHALLENGES → SYSTEM RESPONSE → OUTCOMES

Threats PR & PP Measures & Metrics

Framework is analogous to current approaches to safety analyses and vulnerability assessments





Threat Definition

Proliferation resistance

- Nuclear weapons aspirations (e.g. number and characteristics of explosives)
- Proliferator strategy (e.g. diversion or undeclared production with declared facility, abrogation, clandestine production)
- Proliferator capabilities

Physical protection

- Adversary strategies (e.g. theft of materials, radiological sabotage, operations disruption)
- Class of adversary (e.g. outsiders, insiders, outsiders + insiders)
- Adversary capabilities
- Adversary tactics (e.g. stealth, force, deceit)





System Response – Pathway Analysis

- Pathways: potential sequences of events used by the proliferator or adversary to achieve its objectives (proliferation, theft or sabotage).
- Along any pathway the proliferator or adversary will encounter various deterrents, all of which are collectively called "proliferation resistance" or "physical protection robustness"





Evaluation: Measures and Metrics

- Measure: a major system characteristic that would be an important impediment to the strategy of a proliferant nation (PR), or of a non-state group attempting theft or sabotage (PP).
 - Example: proliferation time
 - the time required to overcome the multiple barriers provided by the system to successful proliferation
- Highest interest is in utilization of intrinsic system features that can contribute to the PR measures.
- System designers can incorporate PR at the early stages of the development by enhancing intrinsic features to maximize impact on PR measures.
 - Iterative process with other design goals





Preliminary PR&PP Measures

- Proliferation Resistance
 - Proliferation Technical Difficulty
 - Proliferation Resources
 - Proliferation Time
 - Fissile Material Quality
 - Detectability
 - Detection Resources





Preliminary PR&PP Measures (cont'd)

- Physical Protection
 - Operational Accessibility
 - Adversary Delay
 - Consequences and Mitigation Potential
 - Detection Time
 - Interruption Delay
 - Physical Protection Resources





Summary of Methodology Development

- PR&PP evaluation method is in development
- Draft definitions of PR & PP measures
- Framework for evaluation defined
- Draft threat space defined
- Focus on user needs: provide feedback to designers and options for policy makers
- Development case now underway
 - Interaction with system developers
 - Evaluation just initiated will assess the usefulness of the current PR&PP measures (Report to DOE and NNSA: 9/2004)





Methodology Development: Conclusions

The successful completion of this systematic evaluation methodology can provide a valuable tool for system developers

- Selection of design choices for enhanced PR&PP
- Integration of safeguards in design





Proliferation Resistant Fuel Cycle Technologies

- Advanced fuel cycle technologies present new challenges to the standard safeguards
- Wider deployment of nuclear systems will also require an increase in safeguards efforts





Proliferation Resistant Fuel Cycle Development

- Joint project between DOE/NA and DOE/NE on proliferation resistance of advanced fuel cycles.
- Work performed jointly by Argonne National Laboratory (ANL) and Los Alamos National Laboratory (LANL).
- Schedule is divided into two phases.
 - Phase 1 Advanced design approach for an advanced fuel cycle facility integrating safeguards.
 - Phase 2 Testing and demonstration of advanced safeguards technologies.
- Phase 1 for an advanced facility based on pyroprocessing technology was completed last year.
- Currently performing Phase 1 for an aqueous facility using UREX+ technology.





Project Objectives

- The project goal is to develop a demonstrably effective safeguards system for advanced fuel processing technologies.
 - Use of an integrated design approach that addresses safeguards issues directly during the design stage.
 - Assessment of the effect of this approach on the safeguardability of the facility.
 - Development and demonstration of advanced safeguards technologies.






Pyroprocessing Project – Phase 1

- Define Generic Pyroprocess Fuel Cycle
 - Define baseline facility layout and process definition
 - Define all flow streams and compositions
- Develop Safeguards Approaches Including Instrumentation and Monitoring Equipment Options
 - Establish expected safeguards requirements for baseline facility
 - Define potential advanced safeguards approaches for baseline facility
- Evaluate, Develop, and Integrate Process, Facility, and Safeguards Instrumentation
 - Assess safeguards approaches and impact of safeguards on facility design and operations
 - Update facility design for integrated safeguards
 - Identify technology needs and demonstration to support safeguards approach





Reference Facility







24

Safeguards - Generic Bulk-Processing Issues

Capacity

- Large throughput places a heavy burden on measurement uncertainties.
- Reference facility will have 2.4 MT TRU/yr. (Rokkasho-mura ~6.4 MT Pu/yr). 1% sigma → 24 kg/yr or 2 kg/mo.
- Can lead to limitations, e.g., on detecting one-year protracted diversion.
 - 3.3 sigma (95% detection probability with 5% false positive) is 79.2 kg/yr which is much greater than 8 kg (IAEA limit).

Initial Pu accountancy

- Largest source of uncertainty in PUREX plants

Heterogeneity

NDA challenged by large batch sizes





Safeguards Approaches

- Iterative process between safeguards approach and impact on facility design and operations
- Four safeguards options have been identified for further study.
 - Neutron Balance-Cm Accounting.
 - Electrorefiner Assay.
 - Homogenized Input.
 - Assay of Pu in Spent Fuel via Pu/Cm ratio and Destructive Analysis.





Example: Electrorefiner Assay Option

- Derive Pu content via synchronized "multi-batch" measurements
 - Assay the Pu content of all U cathodes removed from the ER using a Cm ratio technique similar to that used at the Tokai Reprocessing Plant or DA of U product after processing each day
 - Assay the Pu content of all metal waste baskets removed from the ER during a day using a Cm ratio technique
 - Assay the Pu content and the Pu/Cm ratio in the electrorefiner salt prior to daily salt removal using a DA sample (assuming a homogeneous mixture can be obtained)
 - Weigh the ¼ of the ER salt removed daily and determine Pu content based on the DA sample composition
- Assay the Pu content of the recharge salt and the recovered salts from the metal waste and U product processing units using a Cm ratio technique





Technology Development Needs

- Pin scan plus destructive analysis (DA)
- Homogenization options plus DA
- In-situ assay of Pu in the electrorefiner (ER) plus DA
- Process monitoring options
- Integrated video and radiation monitoring for transfer paths and penetrations
- Waste form measurements
- Near real-time accountability (NRTA) techniques
- Alternative chemical analyses: laser methods





Example – In-situ ER Assay Development

Scope of activities

- Sample electrorefiner salt to demonstrate homogeneity and determine Cm/Pu ratio
- Review of salt level measurement system for DA option
- Determine and install optimal number of fission chambers
- Test and calibrate equipment
- Perform ER Assay measurements
- DA analysis of samples
- Measurement uncertainty
- Examine spoofing possibilities (e.g., ²⁵²Cf source)





Status of Proliferation Resistant Fuel Cycle Technologies Development

- Phase 1 has been completed for pyroprocessing and is ongoing for UREX+
 - Technologies to support the safeguards approaches have been identified for development and demonstration.
- Development and demonstration of the advanced safeguards technologies in Phase 2 (proposed) will enable the determination of preferred safeguards approaches for advanced fuel cycle facilities.





Summary

- Proliferation Resistance will be an important element of the design and deployment of advanced nuclear energy systems
 - Necessary for widespread deployment of nuclear power
- A combination of intrinsic system characteristics and external actions will be necessary to ensure the desirable degree of proliferation resistance





Summary (cont'd)

- An evaluation methodology is in development to permit the assessment of systems and system design options for proliferation resistance.
 - The methodology aims at providing feedback to system developers that can be used during design to enhance PR through intrinsic characteristics
- Advanced safeguards approaches are being developed to enhance the application of external controls to advanced nuclear fuel cycle technologies



